

ESTABLISHED



DEC 14, 1914

**BUREAU OF FIRE PREVENTION**  
205 STATE STREET, HACKENSACK, NEW JERSEY 07601  
TEL: 201.646.7685 FAX: 201.646-7594

Lieutenant Chris Annunziata  
Fire Official  
201.646.3939

Inspector Charles Eyer  
Fire Sub Code Official  
201.646.7806

## **Requirements for all vendors at all Hackensack events**

All vendors shall adhere to the following requirements. Vendors found to be noncompliant will cease operations until requirements are satisfied.

1. All extension cords used shall be; in good condition, rated for outdoor use, 3-prong grounded and rated for the equipment being powered.
2. No cords shall be attached to metal fences or guards.
3. All cords should be in low foot traffic areas and ran at 90 degree angles whenever possible.
4. Any electrical connections to any city owned power sources will be made by the city electrician.
5. Vendors supplying generators for any special equipment shall maintain a fire extinguisher, store fuel in appropriate containers and not refuel while under operation.

### **Vendors Cooking/Preparing Food**

1. Vendors shall maintain at least one fire extinguisher. It shall be at least a 10lb ABC or K type and shall be complete with a current inspection tag or a proof of purchase receipt less than 1 year old.
2. Propane cylinders shall be properly secured and positioned in a safe location.
3. All appliances, hoses, cylinders, connections etc shall be in good condition, free of excessive wear, defects and excessive accumulations of grease.
4. Cooking appliances shall not be used under any canopy unless that canopy is rated flame retardant/fire resistive for use with said appliances.
5. Grills, fryers, etc shall not be set up on plastic table tops or near combustible/flammable items.
6. Overloading tables with cooking appliances shall be prohibited.
7. All appliances (fryers) shall be set up on sturdy level ground.

S M O K E   D E T E C T O R S   S A V E   L I V E S !